

2020  
WATER  
QUALITY  
REPORT

WATER TESTING PERFORMED IN 2019



Simpson County  
Water District

[SIMPSONWATER.COM](http://SIMPSONWATER.COM)

PWSID KY1070398

## WHERE DOES MY WATER COME FROM?

Simpson County Water District purchases water from the White House Utility District (WHUD) in Tennessee. Water treated by WHUD is taken from Old Hickory Lake, a surface water source, and treated at the WHUD treatment plant in Hendersonville, TN. The water is delivered to the Simpson Water distribution network through two delivery points, one located along Hwy 31-W South and the other located near Prices Mill. From these points, water is distributed through 350 miles of water mains ranging in size from 4 inches up to 16 inches in diameter to the homes and businesses served by Simpson Water.

The Safe Drinking Water Act, amended in 1996, requires Community Public Water Systems to prepare a Source Water Assessment Plan (SWAP) report that addresses a water utility's susceptibility to potential sources of contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared the SWAP Report for the untreated water source that is utilized by WHUD.

The source utilized by WHUD is rated reasonably susceptible to potential contamination. An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report submitted to the U.S. Environmental Protection Agency can be viewed online at [www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html](http://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html) or at the Simpson Water office located at 108 Morgantown Road in Franklin, KY. Additional information can be obtained by contacting the Tennessee Division of Water Supply at 1-888-891-8332.

Our goal is to provide the best water and customer service to Simpson County residents. Our customers are our top priority and an important part of our everyday efforts. We continually look for ways to stay involved in our community and to develop ways to educate customers on water quality. Our website, [simpsonwater.com](http://simpsonwater.com), provides customers access to water quality information and facts about their water utility. Also, general brochures, Consumer Confidence Reports (CCRs), and various other Simpson Water publications are available for customer service and educational purposes.

## WATER QUALITY

### Delivering Quality and Commitment in Every Drop!

Simpson Water continually performs numerous tests to ensure your drinking water is safe. Simpson Water tests the purity of the water over 780,000 times a year to ensure the safety of your drinking water. In 2019, the water was tested for over 100 regulated contaminants, and met or exceeded all state and federal quality standards.

\*\*Drinking water, including bottled water, may

reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).\*\*

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

## SPECIAL HEALTH INFORMATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Simpson Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. The good news is that of all the lead testing performed by Simpson Water, there has never been a single sample that exceeded EPA's action level. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 800-426-4791.



# 2019 TEST RESULTS

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

## Regulated Contaminant Test Results

Substance	Compliance Achieved	Report Level	Range of Detection	MCL	MCLG	Tested by	Likely Source
Turbidity (NTU) <sup>1</sup>	YES	0.11	-	-	-	WHUD	Soil Runoff
Fluoride (ppm)	YES	0.66	0.47 to 0.99	4	4	WHUD	Water additive which promotes strong teeth
Total Organic Carbon (ppm) (Measured as ppm, but reported as a percentage)	YES	43% Removal Achieved	25% Removal Required	TT	N/A	WHUD	Naturally present in the environment
Copper (ppm) (Sites exceeding action level: 0)	YES	0.0078 (90th percentile)	0 to 0.0148	AL=1.3	1.3	SCWD (2018)	Corrosion of household plumbing systems
Lead (ppb) (Sites exceeding action level: 0)	YES	0 (90th percentile)	0 to 6	AL=15	0	SCWD (2018)	Corrosion of household plumbing systems
Chlorine (ppm) (Reported as highest avg.)	YES	1.51	0.92 to 2.5	MRDL=4	MRDLG=4	SCWD	Water additive used to control microbes
Haloacetic Acids (ppb) (Reported as highest locational running average)	YES	41	24.0 to 51.7	60	N/A	SCWD	By-product of drinking water chlorination
Total Trihalomethanes (ppb) (Reported as highest locational running average)	YES	48	24.3 to 67.6	80	N/A	SCWD	By-product of drinking water chlorination

<sup>1</sup> No more than 1 NTU, less than 0.3 NTU in 95% of representative samples of filtered water monthly. Lowest monthly percentage was 100%.

Simpson County Water District failed to include some mandatory language in last year's WQR. We have included the required language this year and will include all mandatory language in the future. The omitted language is bordered with \*\* on the previous page (2020-9643714).

## Unregulated Contaminant Test Results

Substance	Average	Range of Detection	Tested by
HAA6Br (ppb)	31.8	22.3 to 47.5	WHUD
HAA9 (ppb)	2.4	0.6 to 4.1	WHUD

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those that EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

## Terms to know when reading the water test results:

### AL (ACTION LEVEL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system shall follow.

### MCL (MAXIMUM CONTAMINANT LEVEL)

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

### MCLG (MAXIMUM CONTAMINANT LEVEL GOAL)

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

### MRDL (MAXIMUM RESIDUAL DISINFECTANT LEVEL)

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary for control of microbial contaminants.

### MRDLG (MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL)

The highest level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

### NTU (NEPHELOMETRIC TURBIDITY UNIT)

A measure of the clarity of water. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

### N/A (NOT APPLICABLE)

Does not apply.

### PPM (PARTS PER MILLION)

One part per million corresponds to one minute in two years, or a single penny in \$10,000.

### PPB (PARTS PER BILLION)

One part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

### TT (TREATMENT TECHNIQUE)

A required process intended to reduce the level of a contaminant in drinking water.

# Simpson Water is Committed to the Community

We are nearing completion of our project to transfer more water along the eastern side of the county to the Wilkey Industrial Park. We expect this new infrastructure to be operational in late August of 2020. The line replacements throughout the county will also be completed around the same time period. Line extensions have been completed to serve 6 new households.

## The Importance of Clean, Safe Drinking Water

The coronavirus pandemic has reinforced that our disinfection process is effective in neutralizing COVID-19. Based on current evidence, the risk to water supplies is low. Americans can continue to use and drink water from their tap as usual. At Warren Water we are taking proactive measures to ensure we can continue to provide our customers with reliable water and wastewater services throughout this crisis. Health officials say the provision of safe water, sanitation and hygienic conditions are essential to protecting human health during all infectious disease outbreaks. Reliable water service used for hygiene, hydration and cooking is critical to our health and safety every day, however, is especially important during a public health emergency. Health organizations recommend that normal hygienic practices, including handwashing for 20 seconds, may play an important role in slowing the spread of the coronavirus.



## A Reminder to Complete your Census.

The U.S. constitution mandates that a census of the population be conducted once every 10 years. Responding to the census is not only your civic duty; it also affects the amount of funding your community receives, how your community plans for the future, and your representation in government. Specifically, data from the 2020 Census are used to:

- Ensure public services and funding for schools, hospitals, and fire departments.
- Plan new homes and businesses and improve neighborhoods.
- Determine how many seats your state is allocated in the House of Representatives.

The 2020 count will be the first to encourage all U.S. households to respond online. However, paper forms will still be available and residents will also be able to complete their census by phone.

### ADDITIONAL INFORMATION ON WATER QUALITY

Simpson County Water District:  
270-598-9926 [simpsonwater.com](http://simpsonwater.com)

White House Utility District (WHUD):  
615-672-411 [whud.org](http://whud.org)

Kentucky Division of Water:  
502-564-3410 [water.ky.gov](http://water.ky.gov)

U.S. EPA Safe Drinking Water Hotline:  
800-426-4791 [epa.gov/safewater/hfacts.html](http://epa.gov/safewater/hfacts.html)

### GET INVOLVED

We strive to maintain a strong relationship with our community, so we continually welcome your comments and the increased opportunity to serve you. Simpson Water Board Meetings are open to the public and are held at 1:00 PM on the fourth Thursday of every month at the Simpson Water office located at 108 Morgantown Rd., Franklin, KY. Please call us at 270-598-9926 for more information.

### THE SIMPSON WATER BOARD OF COMMISSIONERS

Ray Mann - Chairman  
Stephen Snider - Vice Chairman  
Joe Richards - Secretary/Treasurer

### SIMPSON WATER STAFF

John Dix - General Manager  
Ryan Leisey - Manager of Engineering & Construction  
BJ Malone - Manager of IT/GIS  
Tim Minnick - Manager of Construction  
Jeff Peebles - Manager of Finance & Administration  
Alex Renick - Human Resources & Communications Administrator  
Bryan Tillery - Manager of Water Quality/Operations

### ATTENCION

Este informe contiene información muy importante sobre la calidad de su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.



**Simpson County  
Water District**